



STANDARD LEGEND

×	V	Valve
○	M	Meter
□	D.B.	Dirt Box
	S.P.	Straight Piece
▭	L.S.	Line Strainer
∩	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
∩	S.C.V.T	Single Check Valve Testable
∩	S.C.D.A.T.	Single Check Detector Assembly Testable

SCHEDULE OF ITEMS

ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17	6	BALL VALVE
3	BALL VALVE	7	STRAINER TO SUIT BACKFLOW PREVENTION DEVICE MANUFACTURER'S REQUIREMENTS
4	32mm - 50mm DIRT BOX WATER CORPORATION SUPPLIED	8	HIGH / MEDIUM TESTABLE BACKFLOW PREVENTION DEVICE TO AS2845.1
5	APPROVED WATER CORPORATION SUPPLIED WATER METER	SEE GENERAL NOTES FOR FURTHER INFORMATION	

GENERAL NOTES:

- A. Meters 50mm and above to be supported independent of pipework
- B. No connection permitted between water meter and backflow device
- C. Water corporation is responsible for maintenance to the outlet of the main water meter
- D. Meter connection may be screwed or flanged