



WHERE FIRE SERVICES HAVE HOSE REELS IN AREAS SUBJECT TO POTENTIAL INTERCONNECTION WITH CONTAMINANTS, THE TYPE OF BACKFLOW PREVENTION DEVICE INSTALLED AT THE WATER METER MUST BE RELEVANT TO THE HAZARD RATING OF THE PROPERTY.

SCHEDULE OF ITEMS			
ITEM NO.	DESCRIPTION	ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17	6	SPACER 3 x PIPE DIAMETER
3	ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE	7	BACKFLOW PREVENTION DEVICE AND ASSOCIATED VALVING TO BE RELEVANT TO HAZARD RATING – CHECK NOTICE OF AGREEMENT
4	SPACER 5 x PIPE DIAMETER		
5	APPROVED WATER CORPORATION SUPPLIED WATER METER	METERS 50mm AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK	
SEE GENERAL NOTES FOR FURTHER INFORMATION			

STANDARD LEGEND		
×	V	Valve
○	M	Meter
□	D.B.	Dirt Box
	S.P.	Straight Piece
□	L.S.	Line Strainer
≡	B.P.D.	Backflow Prevention Device (Testable or Non-Testable)
≡	S.C.V.T	Single Check Valve Testable
≡	S.C.D.A.T.	Single Check Detector Assembly Testable

DRAWING NUMBER:
11

SCALE:
NOT
TO
SCALE

DATE:
SEPTEMBER
2024

80mm+ FIRE AND GENERAL SERVICE COMBINED
RESIDENTIAL / COMMERCIAL / INDUSTRIAL
TYPICAL ARRANGEMENT

